



Safeguarding lives, property, and the environment through prevention, education, and emergency response.

CARBON MONOXIDE ALARM INSTALLATION

For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms in dwelling units and on each level of the dwelling in accordance with the manufacturer's recommendation.

Carbon monoxide alarms in dwelling units shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms on each level of the dwelling and in accordance with the manufacturer's recommendations. Where a fuel burning appliance is located within a bedroom or its attached bathroom, a carbon monoxide alarm shall be installed within the bedroom.

Combination carbon monoxide and smoke alarms shall be permitted to be used in lieu of carbon monoxide alarms.

Existing dwellings shall be equipped with carbon monoxide alarms when alterations, repairs and additions are made. An Inspection will occur where alterations, repairs, or additions requiring a permit occur, or where one or more sleeping rooms are added or created.



Assistant Chief Luke Carpenter, Fire Marshal

Bainbridge Island Fire Department

8895 Madison Ave.

Bainbridge Island, WA 98110

Office: 206-451-2033

Cell: 206-550-9816

Email: Lcarpenter@bifd.org